



Last Updated February 5, 2013

**FERC Standards of Conduct – Order 2004, Order 717
Indianapolis Power & Light Company Incident Disclosure**

Tuesday, January 29, 2013

On January 29 at 10:52 a.m., a member of the System Energy Coordination (Marketing Function) team reported to the ECS support group that they were able to see live transmission tie line data off of a link on their ECS consoles. The ECS support team determined that viewing restrictions were not enabled on two separate AGC displays. At 11:11 a.m. on January 29th, those displays were recompiled and restricted viewing was corrected and verified. The total time of this violation is unknown but is believed to have started with an ECS software upgrade that was completed on June 15, 2012.